







Address Harregatplein 15
3214 VP Zuidland
Telephone +31 (0) 181 45 21 20
Fax +31 (0) 181 45 21 85
E-mail info@indexelektro.nl
Website www.indexelektro.nl

EU Declaration of Conformity
in accordance with
ATEX Directive 2014/34/EU







Manufacturer	Index Elektro BV	
Address	Harregatplein 15 3214 VP Zuidland the Netherlands	
Product Name	Terminal / Control / Distribution Box	
Type	INDEX.P.Y	with ser.nr.
ATEX Mark	 II 2 G / Ex px/py edm [ia/ib] IIA/IIB/IIC T6 to T3 Gb and/or  II 2 D / Ex pD 21 IP6X T80/95/130°C and/or  II 2 D / Ex t IIB/IIC T80/95/130°C Db IP6X	
Notified Body	ISSeP, Rue de la Platinerie, B-7340 Colfontaine, Belgium (0492)	
Certificate no.	ISSeP09ATEX032X	
Quality Assurance	CML (Certification Management Limited), Unit 1 Newport Business Park, New Port Road, Ellesmere Port CH65 4LZ, UK	
Notified Body no.	2776	
Applicable Standards	EN 60079-0: 2006	EN 60079-2: 2007 EN 61241-0: 2006
		EN 61241-4: 2004 IEC 60079-31: 2008, compliance is not affected by EN60079-0: 2012
Declaration	The undersigned, representing the manufacturer, herewith declares that the object of the declaration described above is in conformity with the relevant Union harmonisation legislation Directive 2014/34/EU (from April 20th, 2016), when installed and maintained in accordance with the 'Safety and Maintenance Instruction'.	
Name	Ron den Hartigh	
Position	Authorized representative for ATEX	
Signature		
Date	16-9-2024	



Address Harregatplein 15
3214 VP Zuidland
Telephone +31 (0) 181 45 21 20
Fax +31 (0) 181 45 21 85
E-mail info@indexelektro.nl
Website www.indexelektro.nl

EU Declaration of Conformity
in accordance with
ATEX Directive 2014/34/EU



Manufacturer	Index Elektro BV	
Address	Harregatplein 15 3214 VP Zuidland the Netherlands	
Product Name	Terminal / Control / Distribution Box	
Type	INDEX.E.Y.606025L with ser.nr. 211318-15557	
ATEX Mark	 II 3 G / Ex pz edm [ia/ib] IIA/IIB/IIC T6 to T3 Gc and/or  II 3 D / Ex pD 22 IP6X T80/95/130°C and/or  II 3 D / Ex t IIIB/IIIC T80/95/130°C Dc IP6X	
Notified Body	ISSeP, Rue de la Platinerie, B-7340 Colfontaine, Belgium (0492)	
Certificate no.	ISSeP09ATEX033X	
Quality Assurance	CML B.V., Hoogoorddreef 15, Amsterdam, 1101 BA, The Netherlands	
Notified Body no.	2776	
Applicable Standards	EN 60079-0: 2006 EN 60079-2: 2007 EN 61241-0: 2006 EN 61241-4: 2004 IEC 60079-31: 2008, compliance is not affected by EN60079-0: 2012	
Declaration	The undersigned, representing the manufacturer, herewith declares that the object of the declaration described above is in conformity with the relevant Union harmonisation legislation Directive 2014/34/EU (from April 20th, 2016), when installed and maintained in accordance with the 'Safety and Maintenance Instruction'.	
Name	Ron den Hartigh	
Position	Authorized representative for ATEX	
Signature		
Date	16-9-2024	