



Address Harregatplein 15
3214 VP Zuidland
Telephone +31 (0) 181 45 21 20
E-mail info@indexelektro.nl
Website www.indexelektro.nl

EU Declaration of Conformity
in accordance with
ATEX Directive 2014/34/EU



Manufacturer	Index Elektro BV						
Address	Harregatplein 15 3214 VP Zuidland the Netherlands						
Product Name	Cable glands type IR** and IB**						
ATEX Mark	<table><tr><td> II 2 G / Ex db IIC Gb</td><td> I M2 / Ex db II Mb</td></tr><tr><td> II 2 G / Ex eb IIC Gb</td><td> I M2 / Ex eb II Mb</td></tr><tr><td> II 2 D / Ex tb IIIC Db</td><td></td></tr></table>	II 2 G / Ex db IIC Gb	I M2 / Ex db II Mb	II 2 G / Ex eb IIC Gb	I M2 / Ex eb II Mb	II 2 D / Ex tb IIIC Db	
II 2 G / Ex db IIC Gb	I M2 / Ex db II Mb						
II 2 G / Ex eb IIC Gb	I M2 / Ex eb II Mb						
II 2 D / Ex tb IIIC Db							
Notified Body	APRAGAZ						
Certificate no.	APRAGAZ 24 ATEX 0238X						
Quality Assurance	CML B.V., Koopvaardijweg 32, Oosterhout, 4906 CV, The Netherlands						
Notified Body no.	2776						
Applicable Standards	EN IEC 60079-0 - 2018 / AC:2020-02 EN 60079-1 - 2014 EN IEC 60079-7 - 2015 / A1:2018 EN 60079-31 - 2014						
Declaration	<p>The undersigned, representing the manufacturer, herewith declares that the object of the declaration described above is in conformity with the relevant Union harmonisation legislation Directive 2014/34/EU (from April 20th, 2016), when installed and maintained in accordance with the 'Safety and Maintenance Instruction'.</p> <p>GAP analysis has been done. The equipment is compliant with the latest edition of the Standards.</p>						
Name	Ron den Hartigh						
Position	Authorized representative for ATEX						
Signature							
Date	9-7-2024						