




## EU Type Examination Certificate CML 17ATEX1249X Issue 2

- 1 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 2 Equipment **Z086, Z136 and Z0264 Series Explosion-proof (Emergency) LED Linear Light Fittings**
- 3 Manufacturer **Index Elektro B.V.**
- 4 Address Harregatplein 15  
3214VP  
Zuidland  
The Netherlands
- 5 The equipment is specified in the description of this certificate and the documents to which it refers.
- 6 CML B.V., Chamber of Commerce No 6738671, Koopvaardijweg 32, 4906CV Oosterhout, The Netherlands, Notified Body Number 2776, in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.  
  
The examination and test results are recorded in the confidential reports listed in Section 12.
- 7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to conditions of safe use (affecting correct installation or safe use). These are specified in Section 14.
- 8 This EU Type Examination certificate relates only to the design and construction of the specified equipment or component. Further requirements of Directive 2014/34/EU Article 13 apply to the manufacture of the equipment or component and are separately certified.
- 9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:  

|                             |                              |                  |
|-----------------------------|------------------------------|------------------|
| EN 60079-0:2018             | EN 60079-1:2014*             | EN 60079-5:2015  |
| EN IEC 60079-7:2015+A1:2018 | EN IEC 60079-18:2015+A1:2017 | EN 60079-31:2014 |

- 10 The equipment shall be marked with the following:



Ex db eb mb q IIC T6/T5/T4 Gb  
Ex tb IIIC T80°C Db  
Ta = -25°C to +40°C/+50°C/+55°C  
*Refer to description for complete marking.*





CML 17ATEX1249X  
Issue 2

## 11 Description

The Z086 Series, Z136 Series and Z0264 Series Explosion-proof (Emergency) LED Linear Light Fittings are designed for fixed location hazardous areas and rated at 100V to 250V AC/DC unless otherwise stated below. They are installed to run from cabled power supplies but also include the option for emergency batteries.

The enclosures are IP66 rated and incorporate the use of the Explosion-proof LED Light Modules Z1618/11-LED\_\_W\_ and Z1618/11B-LED\_\_W\_, the Explosion-proof LED Power Modules Z1618/57-\_x LED\_\_W and Z1618/57B-LED\_\_W, the Explosion-proof LED Inverter Modules Z1618/58-\_x LED\_\_W and Z1618/58B-LED\_\_W which are certified under CML 16 ATEX 3341U and IECEx CML 16.0115U, the MU025HyAQ\_MB/z LED driver certified under IECEx TPS 21.0008U, and the MU060HyAQ\_MB/z LED driver certified under IECEx TPS 21.0011U.

There are also options for the inclusion of Z0819 Series Explosion-proof battery module, the Z0207 series Explosion-proof isolation switch module which is certified under IECEx CQM 15.0034U, the Z0804 series explosion-proof fuse module which is certified under IECEx CQM 11.0009U, and the Z0212 Signal lamp and button module certified under IECEx CML 19.0054U.

The models are marked and are rated as below:

### Z086 Series

| Type                                   | Gasket type     | Gas Classification            | Ambient temperature range | Dust Classification    | Rating                |
|--|-----------------|-------------------------------|---------------------------|------------------------|-----------------------|
| Z086x<br>Standard<br>without<br>switch | Silicone rubber | Ex eb mb q IIC T5/T4<br>Gb    | -<br>25°C≤Ta≤+40°C/+55°C  | Ex tb IIIC T80°C<br>Db | AC100-250V<br>50/60Hz |
|  | Polyurethane    | Ex eb mb q IIC T5 Gb          | -25°C≤Ta≤+40°C            |                        |                       |
| Z086x<br>Standard<br>with switch       | Silicone rubber | Ex db eb mb q IIC T5/T4<br>Gb | -<br>25°C≤Ta≤+40°C/+55°C  |                        |                       |
|  | Polyurethane    | Ex db eb mb q IIC T5<br>Gb    | -25°C≤Ta≤+40°C            |                        |                       |
| Z0865<br>Emergency                     | Silicone rubber | Ex db eb mb q IIC T4<br>Gb    | -25°C≤Ta≤+50°C            |                        |                       |
|  | Polyurethane    |                               | -25°C≤Ta≤+40°C            |                        |                       |
| Z0866<br>Emergency                     | Silicone rubber | Ex db eb mb q IIC T4<br>Gb    | -25°C≤Ta≤+55°C            |                        |                       |
|  | Polyurethane    |                               | -25°C≤Ta≤+40°C            |                        |                       |

-

### - Z136x Series

| Type       | Gas Classification      | Ambient temperature range | Dust Classification | Rating                |
|------------|-------------------------|---------------------------|---------------------|-----------------------|
| All models | Ex db eb mb q IIC T6 Gb | -25°C≤Ta≤+40°C            | Ex tb IIIC T80°C Db | AC/DC100-250V 50/60Hz |
|            | Ex db eb mb q IIC T5 Gb | -25°C≤Ta≤+55°C            |                     |                       |



**CML 17ATEX1249X  
Issue 2**

**- Z0264 Series**

| Type       | Gasket type     | Gas Classification      | Ambient temperature range | Dust Classification | Rating                   |
|------------|-----------------|-------------------------|---------------------------|---------------------|--------------------------|
| All models | Silicone rubber | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+55°C            | Ex tb IIIC T80°C Db | AC/DC100-250V<br>50/60Hz |
|            |                 | Ex db eb mb q IIC T6 Gb | -40°C≤Ta≤+40°C            |                     |                          |
|            | Polyurethane    | Ex db eb mb q IIC T6 Gb | -40°C≤Ta≤+40°C            |                     |                          |

**- Z186 Series**

| Type   | Gasket type     | Gas Classification      | Ambient temperature range | Rating                               | Dust Classification |
|--|-----------------|-------------------------|---------------------------|--------------------------------------|---------------------|
| Z1865 Standard with Z1618/57B driver               | Silicone rubber | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+55°C            | AC/DC100-250V<br>50/60Hz             | Ex tb IIIC T80°C Db |
|  |                 | Ex db eb mb q IIC T6 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb q IIC T6 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
| Z1865 Emergency                                    | Silicone rubber | Ex db eb mb q IIC T4 Gb | -40°C≤Ta≤+55°C            |                                      |                     |
|  |                 | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
| Z1866 Standard with Z1618/57B driver and Emergency | Silicone rubber | Ex db eb mb q IIC T4 Gb | -40°C≤Ta≤+55°C            |                                      |                     |
|  |                 | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
| Z1866 Emergency                                    | Silicone rubber | Ex db eb mb q IIC T4 Gb | -40°C≤Ta≤+55°C            |                                      |                     |
|  |                 | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb q IIC T5 Gb | -40°C≤Ta≤+40°C            |                                      |                     |
| Z1865 Standard with MU025xx driver                 | Silicone rubber | Ex db eb mb IIC T5 Gb   | -40°C≤Ta≤+55°C            | AC100-250V<br>50/60Hz<br>DC 125-250V |                     |
|  |                 | Ex db eb mb IIC T6 Gb   | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb IIC T6 Gb   | -40°C≤Ta≤+40°C            |                                      |                     |
| Z1866 Standard with MU060xx driver                 | Silicone rubber | Ex db eb mb IIC T5 Gb   | -40°C≤Ta≤+55°C            |                                      |                     |
|  |                 | Ex db eb mb IIC T6 Gb   | -40°C≤Ta≤+40°C            |                                      |                     |
|  | Polyurethane    | Ex db eb mb IIC T6 Gb   | -40°C≤Ta≤+40°C            |                                      |                     |



CML 17ATEX1249X  
Issue 2

#### Variation 1:

This variation introduced the following modifications:

- i. The introduction of the Z0264 range.
- ii. Clarification of the marking options available to the ranges covered.
- iii. Amending of the product description and a specific condition of use, to account for the above modifications.
- iv. Recognition of the previous transfer from CML UK to CML B.V., on the certificate.

#### Variation 2:

This variation introduced the following modifications to the trade agent certification:

- i. The introduction of an alternative power module and LED light source in the Z136 model
- ii. Changes to the operating temperature range of the Z0264 model
- iii. The introduction of an alternative power module and LED light source in the Z0264 model
- iv. The use of alternative enclosure materials in the Z0264 model
- v. The introduction of new LED luminaire type Z186
- vi. The removal of "op is" marking from all models, and removal of IEC/ EN 60079-28 from the certificates.
- vii. Update of standards IEC/EN IEC 60079-0, IEC/EN IEC 60079-7 & IEC/EN IEC 60079-18.

## 12 Certificate history and evaluation reports

| Issue | Date        | Associated report | Notes                       |
|-------|-------------|-------------------|-----------------------------|
| 0     | 29 Sep 2017 | R11354A/00        | Issue of prime certificate  |
| 1     | 14 Jun 2021 | R13951B/00        | Introduction of Variation 1 |
| 2     | 05 Jul 2023 | R16539A/00        | Introduction of Variation 2 |

Note: Drawings that describe the equipment or component are listed in the Annex.

## 13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the equipment incorporates certified parts or safety critical components, the manufacturer shall ensure that any changes to those parts or components do not affect the compliance of the certified product that is the subject of this certificate. A copy of the certification and/or instructions for the parts shall be provided as part of the luminaire document pack.
- ii. Each unit manufactured shall be subjected to an electric strength test in accordance with EN 60079-7:2015 clause 7.1. It shall be carried out at 1,000 V + 2U for 60 seconds or at 1.2 times this test voltage for at least 100 ms.



**CML 17ATEX1249X  
Issue 2**

#### **14 Specific Conditions of Use (Special Conditions)**

The following conditions relate to safe installation and/or use of the equipment.

- i. Due to the risk of static hazards of the Z086 Series, Z0264, and Z186 Series Luminaire Ranges, the equipment in these ranges shall only be cleaned with a damp cloth.
- ii. Z186 models incorporating MU025xx or MU060xx drivers shall only be connected to an electrical power supply which is fitted with a protective device which limits the current to a maximum of 10A.
- iii. The cable entries shall be made via suitably certified cable glands providing an ingress protection of IP66. Any unused entries shall be closed with suitably certified blanking plugs providing a degree of protection of IP66.
- iv. Z186 models contain a flameproof switch. The dimensions of the flameproof joints differ from those of EN/IEC 60079-1 Table 2 and therefore shall not be repaired.
- v. The power and inverter modules fitted inside the luminaire enclosure are supplied permanently sealed and therefore no attempt must be made to open or repair them.

## Certificate Annex

Certificate Number

Equipment

Manufacturer



The following documents describe the equipment or component defined in this certificate:

### Issue 0

| Drawing No     | Sheets | Rev | Approved date | Title                  |
|----------------|--------|-----|---------------|------------------------|
| 8Z0865.015.000 | 1 of 1 | -   | 29 Sep 2017   | Type - Z0865 - Labels  |
| 8Z0866.015.000 | 1 of 1 | -   | 29 Sep 2017   | Type - Z0866 - Labels  |
| 8Z1361.015.000 | 1 of 1 | -   | 29 Sep 2017   | Type - Z.1361 - Labels |
| 8Z1362.015.000 | 1 of 1 | -   | 29 Sep 2017   | Type - Z.1362 - Labels |

### Issue 1

| Drawing No     | Sheets | Rev | Approved date | Title                   |
|----------------|--------|-----|---------------|-------------------------|
| 8Z0264.015.001 | 1 of 1 | 0   | 11 Jun 2021   | Type – Z0264/1 – Labels |
| 8Z0865.015.000 | 1 of 1 | 3   | 11 Jun 2021   | Type – Z0865 – Labels   |
| 8Z0866.015.000 | 1 of 1 | 3   | 11 Jun 2021   | Type – Z0866 – Labels   |
| 8Z1361.015.000 | 1 of 1 | 2   | 11 Jun 2021   | Type – Z.1361 – Labels  |
| 8Z1362.015.000 | 1 of 1 | 2   | 11 Jun 2021   | Type – Z.1362 – Labels  |

### Issue 2

| Drawing No     | Sheets | Rev | Approved date | Title                 |
|----------------|--------|-----|---------------|-----------------------|
| 8Z0865.015.000 | 1 of 1 | 3   | 05 Jul 2023   | Type – Z0865 – Labels |
| 8Z0866.015.000 | 1 of 1 | 3   | 05 Jul 2023   | Type – Z0866 – Labels |